



## ST. TAMMANY PARISH

PATRICIA P. BRISTER  
PARISH PRESIDENT

**August 31, 2017**

Please find the following addendum to the below mentioned QUOTE.

**Addendum No.:** 1

**Quote#:** 311-00-17-63-1

**Project Name:** Huntington Drainage Improvement Phase 2

**Quote Due Date:** Thursday, September 7, 2017

### **QUESTIONS & ANSWERS:**

---

**Question #1:** We have a question that we would like to know. In the General notes, Note 11, in the plans it tells the contractor to maintain traffic on driveways and that traffic aggregate shall be furnished and installed to maintain traffic at driveways. There is no pay item for traffic aggregate. Please advise.

**Answer #1:** No traffic maintenance aggregate is required. Contractor will notify residents beforehand to make accommodations for residents to park on street while driveways are being replaced.

**<< End of Addendum #1 >>**